



15 September 2020

21. Sample Nr 199943	Substrate Details
Substrate Type	Structural Glazing Foam Tape
Substrate Mnf Name / Supplier Name	Rubberlite / H&O Products
Mnf code / Batch Number	SGT T2040
Substrate Description	Black double sided glazing tape
Surface to test	Uniform Surface
Sealant	Application Recommendation
DOWSIL™ 121 Structural Glazing Sealant	Approved for Contact in Structural and Weatherseal Applications
DOWSIL™ 756 SMS Building Sealant	Approved for Contact in Weatherseal Applications
DOWSIL™ 791 Silicone Weatherproofing Sealant	Approved for Contact in Weatherseal Applications
DOWSIL™ 983 Structural Glazing Sealant	Approved for Contact in Structural and Weatherseal Applications

22. Sample Nr 199944	Substrate Details
Substrate Type	Silicone Setting Block
Substrate Mnf Name / Supplier Name	Diversified Silicone Products / H&O Products
Mnf code / Batch Number	1/4" x 1" x 11" Setting Block
Substrate Description	DSP80CG 80 durometer black silicone setting block
Surface to test	Uniform Surface
Sealant	Application Recommendation
DOWSIL™ 121 Structural Glazing Sealant	Approved for Contact in Structural and Weatherseal Applications
DOWSIL™ 756 SMS Building Sealant	Approved for Contact in Weatherseal Applications
DOWSIL™ 791 Silicone Weatherproofing Sealant	Approved for Contact in Weatherseal Applications
DOWSIL™ 983 Structural Glazing Sealant	Approved for Contact in Structural and Weatherseal Applications

*Plasticizers from the tested material migrated through the sealant and oxidized (or discolored) on the sealant surface. Dark color sealant is recommended to minimize or hide the discoloration that was observed.

The Compatibility tests are performed in accordance to the Modified ASTM C1087. A summary of this laboratory testing / evaluation and application recommendation is listed above.

DOW HIGH PERFORMANCE BUILDING
Imagine the Possibilities
consumer.dow.com/Construction

DOWSIL™

silicones by

AMERICAS
Sealant Test Lab, DC-4, Lab 3A4
2200 W.Salzburg Road
Auburn, MI 48611
USA
Phone : + 1-800-346-9882
americas.cool@dow.com

ASIA
Shanghai Dow Center
936 Zhangheng Road
Pudong District, Shanghai
201203 P. R. China
Phone: +86 21 38511100
asia.cool@dow.com

EMEAI
Parc Industriel – Zone C
B-7180 Seneffe
Belgium
Phone: + 32 (0) 64 511 156
Fax: +32 (0) 270 62 319
emeai.cool@dow.com



The Dow Chemical Company

15 September 2020

Sincerely,

Matthew Schafka
BUSINESS DEVELOPMENT PROFESSIONAL
Tel: +1 415 9716006
Email: MATTHEW.SCHAFKA@DOW.COM

CC: Distributor - S & S PANEL SALES CORPORATION
Address: 647 THOMAS ROAD BENSENVILLE, Illinois 60106-1622 United States

DOW HIGH PERFORMANCE BUILDING
Imagine the Possibilities
consumer.dow.com/Construction

DOWSIL™

silicones by

AMERICAS
Sealant Test Lab, DC-4, Lab 3A4
2200 W.Salzburg Road
Auburn, MI 48611
USA
Phone : + 1-800-346-9882
americas.cool@dow.com

ASIA
Shanghai Dow Center
936 Zhangheng Road
Pudong District, Shanghai
201203 P. R. China
Phone: +86 21 38511100
asia.cool@dow.com

EMEAI
Parc Industriel – Zone C
B-7180 Seneffe
Belgium
Phone: + 32 (0) 64 511 156
Fax: +32 (0) 270 62 319
emeai.cool@dow.com